

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. U2653223S37693762

Dated: 04/07/2026

It is certified that an inspection team headed by Shalini Shukla, Lab Incharge, District Level Water Analysis Laboratory, Sitapur (Name of officers with designation) from UP Jal Nigam (Rural) Sitapur (Name of Department/office) Inspected the APS INTERNATIONAL SCHOOL, Gondlamau Kuchlaai Sitapur, Uttar Pradesh 261403 (Name & Address of the school) on 02-07-2026 (Date of inspection) and on the basis of water test report (Attached) Report no. U2653223S37693762 dated 02-07-2026 of District Level Water Analysis Laboratory, Sitapur (PHED) lab certified that the APS INTERNATIONAL SCHOOL, Gondlamau Kuchlaai Sitapur, Uttar Pradesh 261403 (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T. Govt.

Note:

This certificate is valid till 01 Year from date of issue. In case, if there is any change in Drinking Source/gone under maintenance before Expiry of certificate, then this certificate will be no more valid. School will also need to maintain same water source condition. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Sitapur.

Signature with Seal.....

Name Santosh Singh सहायक अभियन्ता

Designation..... A.E. उ०प्र० जल निगम (ग्रामीण) सीतापुर

Name & Address of the office/Department

Arya Nagar Water Tank Sitapur

To

APS INTERNATIONAL SCHOOL

Gondlamau Kuchlaai Sitapur, Uttar Pradesh 261303

(Name & Address of the Institution)

APS International School

Director/Manager

Principal
APS International School
Kuchlai Gopalpur Bhatta Sidhaur
Sitapur



Analysis Report
District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India
Address : Arya Nagar Water Tank , Sitapur

Rept No	U2653223537693762	Date	04-07-2026	Page No.	1
Customer Name	APS INTERNATIONAL SCHOOL				

Basic details of sample			
District	SITAPUR	Block	Gondlarnau
Gram Panchayat	Kuchlasi	Village/Mohalla	Kuchlasi
Habitation	Kuchlasi	Location/Site Name	Kuchlasi (School Campus Area)
Water Source	Borewell	Sample No.	48731
Quantity of Sample	1L	Date of Sample Collection	02-07-2026
Receiving Date	02-07-2026	Sample Collector	By client
Sample Depositer	By client	Sampling Method	17614 Part 01
Analysis Start Date	02-07-2026	Analysis Completion Date	04-07-2026

Technical Data of Analysis						
S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25°C	-	7.18	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022
2	Turbidity	(NTU)	0.38	1	5	IS 3025 (Part 10) : 2023
3	TDS	(mg/L)	338	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	24	250	1000	IS 3025 (Part 32) : 2019
5	Total Alkalinity	(mg/L)	204	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	(mg/L)	180	200	600	IS 3025 (Part 21) : 2019
7	Calcium	(mg/L)	16	75	200	IS 3025 (Part 40) : 2023
8	Magnesium	(mg/L)	34.02	30	100	IS 3025 (Part 46) : 2023
9	Sulphate	(mg/L)	BDL	200	400	APHA 24 Edition -4500 SO ₄ method (Turbidity method): 2023
10	Nitrate	(mg/L)	2.25	45	45	APHA 24 Edition -4500 NO ₃ method B (UV Spectrophotometric method): 2023
11	Fluoride	(mg/L)	0.11	1	1.5	APHA 24 Edition -4500-F Method C (Electrode Method) : 2023
12	Iron	(mg/L)	BDL	1	No relaxation	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
13	Color	Hazen	<5	5	15	IS 3025 (Part 4) : 2021

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (In case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL Stands for Below Deduction Line that means water is in safe range.

Authorized Signatory


Chemist
Shallini Shukla


Laboratory Contact details :- Email - stplabupjalnigam@gmail.com , Mob :- +91 8318597887

LAB INCHARGE

District Level Water Analysis Laboratory
UPJN (RURAL) SITAPUR

End of the report


Principal
APS International School
Kuchlasi Gopalpur Bhatta Sidhauri
Sitapur

APS International School

Director/Manager



Analysis Report
District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India

Rept No. | 02653223537693762

Date

04-07-2026

Page No.

1

Customer Name | APS INTERNATIONAL SCHOOL

Basic details of sample

District	SITAPUR	Block	Gonilamau
Gram Panchayat	Kuchlaal	Village/Mohalla	Kuchlaal
Habitation	Kuchlaal	Location/Site Name	Kuchlaal (School Campus Area)
Water Source	Borewell	Sample No.	48731
Quantity of Sample	1L	Date of Sample Collection	02-07-2026
Receiving Date	02-07-2026	Sample Collector	By client
Sample Depositer	By client	Sampling Method	17614 Part 01
Analysis Start Date	02-07-2026	Analysis Completion Date	04-07-2026

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.coli	-	0.0	Shall Not Be Deducted in 100 ml sample		APIIA 24th Edition -9211B
2	T.coll	-	0.0	Shall Not Be Deducted in 100 ml sample		APIIA 24th Edition -9211B

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (In case of non perishable items only) from the date of issue of test reports unless otherwise specified.

Prepared By

Microbiologist

Authorized Signatory

Microbiologist
Saumya Gupta

Laboratory Contact details :: Email - stplabupjalnigam@gmail.com, Mob -: +91 8310597887

End of the report

Principal
APS International School
Kuchlai Gopalpur Bhatta Sidhauri
Sitapur

APS International School

Director/Manager